



WATER MAIN LAYOUT LEGEND

- EXISTING WATERMAIN
- (FH) EXISTING FIRE HYDRANT
- PROPOSED WATERMAIN 75mm ϕ (PE80)
- 25mm ϕ SERVICE CONNECTION FROM BOUNDARY BOX
- [M] PROPOSED STOPCOCK AND WATER METER BOUNDARY BOX
- (FH) PROPOSED FIRE HYDRANT
- [S] PROPOSED SLUICE VALVE
- [P] PROPOSED MARKER POST & INDICATOR PLATE
- [Sv] PROPOSED SCOUR VALVE
- TB PROPOSED THRUST BLOCK

- GENERAL NOTES:**
- ALL DIMENSIONS AND LEVELS TO BE VERIFIED ON SITE PRIOR TO COMMENCEMENT OF THE WORKS. ANY DISCREPANCIES TO BE REPORTED TO THE ENGINEER.
 - THIS DRAWING IS TO BE READ IN CONJUNCTION WITH THE RELEVANT ARCHITECT'S AND OTHER ENGINEERING DRAWINGS.
- WATERMAIN NOTES:**
- ALL WATERMANS AND SUPPLY SHOULD BE CONSTRUCTED TO IRISH WATER REQUIREMENTS AND IN ACCORDANCE WITH IRISH WATER CONNECTIONS & DEVELOPER SERVICES WATER INFRASTRUCTURE STANDARD DETAILS IW-CDS-5020-03 JULY 2020.
 - THE CONTRACTOR SHOULD CONFIRM THE LOCATIONS OF ALL EXISTING WATERMAIN INFRASTRUCTURE ON SITE AND REPORT TO THE ENGINEER.
 - WATERMAIN PIPES SHOULD HAVE A MINIMUM NOMINAL PRESSURE CLASSIFICATION OF 10 BAR. uPVC PRESSURE PIPES SHALL CONFORM TO UK WATER INDUSTRY SPECIFICATION NO 4-31-08 OR EQUIVALENT. MANUFACTURERS SHALL OPERATE A QUALITY SYSTEM IN COMPLIANCE WITH BS 5750 PART 2 (EN29002).
 - WATERMAIN PIPES SHOULD HAVE A MINIMUM COVER OF 900mm
 - AN APPROVED MARKER TAPE CONTAINING A TRACER WIRE SHOULD BE AFFIXED TO THE TOP SURFACE OF ALL WATERMANS
 - CONCRETE THRUST BLOCKS SHOULD BE PROVIDED ON WATERMANS AT DEAD ENDS, TEES, BENDS OF CURVATURE GREATER THAN 11.25° AND AT BOTH SIDES OF A SLUICE VALVE CHAMBER. ANCHOR BLOCKS SHOULD ENCASE THE PIPE IN CONCRETE (CLASS E, CLAUSE 1502, SPECIFICATION FOR ROADWORKS) TO A MINIMUM THICKNESS OF 150mm ALL ROUND AND SHOULD BE A MINIMUM LENGTH OF 750mm
 - SLUICE VALVES SHOULD COMPLY WITH THE REQUIREMENTS OF BS 5163. THE DEPTH OF THE SLUICE VALVE SPINDLE CAP BELOW FINISHED GROUND LEVEL SHOULD NOT EXCEED 300mm
 - HYDRANTS SHOULD BE OF THE MALE THREAD SCREW DOWN TYPE IN COMPLIANCE WITH THE REQUIREMENTS OF BS 750. HYDRANT OUTLETS SHOULD COMPLY WITH THE CHIEF FIRE OFFICERS REQUIREMENTS. THE DEPTH OF THE HYDRANT OUTLET BELOW FINISHED GROUND LEVEL SHOULD NOT EXCEED 200mm
 - SCOUR VALVES TO BE LOCATED AT LOW POINTS AND AIR VALVES AT HIGH POINTS ALONG THE VERTICAL PROFILE OF THE WATERMAIN. CONTRACTOR TO AGREE SPECIFICATION FOR VALVES WITH WESTMEATH COUNTY COUNCIL.
 - CONTRACTOR TO ALLOW FOR ROAD OPENING UP LICENCE FOR WORKS IN PUBLIC ROAD, WHERE NECESSARY.

REV	DATE	DESCRIPTION	BY	APPR
C	23.05.22	UPDATED WITH LATEST LAYOUT	FR	MK
B	23.06.21	EXISTING WM LAYOUT UPDATED FOLLOWING RECEIPT OF GBR SURVEY	FM	MK
A	28.04.21	UPDATED AFTER WCC COMMENTS	FM	MK

DRAWING STATUS:
PART_8

CLIENT:
WESTMEATH COUNTY COUNCIL

JOB DESCRIPTION:
15No. RAPID BUILD HOUSING UNITS, ENNELL COURT, MULLINGAR, COUNTY WESTMEATH

DRAWING TITLE:
INDICATIVE WATERMAIN LAYOUT
2 OF 2

PROJECT No.:	DRAWING No.:
P-3457	C-108
REV. No.:	
C	

SCALE:	SHEET:	DATE:
1:250	A1	21.09.2020
DRAWN BY:	CHECKED BY:	APPROVED BY:
JR	MK	PMCM

McMahon Associates
Consulting Civil & Structural Engineers, Traffic Engineers
PSDP/CDM Principal Designer, Project Managers

Armagh Drogheda Croydon
(028) 3752 2940 (041) 2137050 (0208) 2636051
e: info@mcmahonengineers.com

INDICATIVE WATERMAIN LAYOUT 2 OF 2
SCALE 1:250